



Test Report Summary

Product Information	
Licence Number:	214439
Licensee:	Roth-France SAS
Product Identification	Centrale CR30-ZE5 (item no. 1409101120)
Test Specifications	
Tested Application:	Water Floor Heating Systems
Temperature Sensor	
- Type:	Sentech IN-A010K-D824-BK-25MM
- Time Constant:	10 Mins
Actuator Identification	Roth Certiline MV-SK
- Type:	BX
Valve Identification	RothHX-D,NIS,Inox,THERMASET,Zone control valve set
- Characteristic	2-way/3-way valve: linear
AV Acronym	BP/**/**/23WV/L
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy C_A according EN 15500	0.3

08 March 2021

Brussels

Managing Director Dr. Peter Hug

eu.bac